

CUADRO DE REGULACION TEORAMA																					
CUADRO DE REGULACION										TABLERO		CTO		VL		240		SUBESTACION		MONOFASICO	
Centralizado (1) 5 KW																					
DE	A	LONG	CARGA	TOTAL	F.P.	KVAT	MOM	FASE/LINE	IF	COND	IFSE	COND	INCOND	KG	FC	PARC	TOTAL				
		MW	KW	KW		KVA	KVA-M	AS	(A)	/ASE	(A)		(A)			%	%				
Instalación	C1	31	3	3.81	0.90	4.23	129.35	2	17.62	1	17.62	C-AL No 2 THW	90.00	91.09	2.00	0.41	0.41				
Instalación	C2	40	2	2.54	0.90	2.82	112.78	2	11.75	1	11.75	C-AL No 2 THW	90.00	91.09	2.00	0.36	0.76				
Instalación	C3	154	1	1.27	0.90	1.41	217.76	2	5.87	1	5.87	C-AL No 2 THW	90.00	91.09	2.00	0.09	1.45				
USUARIOS	5	REGULACION MAXIMA															1.45				
Centralizado 10 KW																					
DE	A	LONG	CARGA	TOTAL	F.P.	KVAT	MOM	FASE/LINE	IF	COND	IFSE	COND	INCOND	KG	FC	PARC	TOTAL				
		MW	KW	KW		KVA	KVA-M	AS	(A)	/ASE	(A)		(A)			%	%				
Instalación	C1	30	15	15.03	0.90	21.15	634.38	2	88.11	1	88.11	AA2	135.00	106.00	2.00	2.33	2.33				
Instalación	C2	40	9	11.42	0.90	12.69	507.50	2	52.86	1	52.86	AA2	135.00	106.00	2.00	1.87	4.20				
Instalación	C3	30	4	5.08	0.90	5.64	166.77	2	23.50	1	23.50	AA2	135.00	106.00	2.00	0.62	4.82				
USUARIOS	15	REGULACION MAXIMA															4.82				
Centralizado (2) 5 KW																					
DE	A	LONG	CARGA	TOTAL	F.P.	KVAT	MOM	FASE/LINE	IF	COND	IFSE	COND	INCOND	KG	FC	PARC	TOTAL				
		MW	KW	KW		KVA	KVA-M	AS	(A)	/ASE	(A)		(A)			%	%				
Instalación	C1	30	8	10.15	0.90	11.28	338.33	2	46.99	1	46.99	AA2	135.00	106.00	2.00	1.25	1.25				
Instalación	C2	31	2	2.54	0.90	2.82	88.28	2	11.75	1	11.75	AA2	135.00	106.00	2.00	0.32	1.57				
USUARIOS	8	REGULACION MAXIMA															1.57				
Centralizado 15 KW																					
DE	A	LONG	CARGA	TOTAL	F.P.	KVAT	MOM	FASE/LINE	IF	COND	IFSE	COND	INCOND	KG	FC	PARC	TOTAL				
		MW	KW	KW		KVA	KVA-M	AS	(A)	/ASE	(A)		(A)			%	%				
Instalación	C1	11	13.32	13.32	0.90	15.51	494.26	2	64.61	1	64.61	AA2	135.00	106.00	2.00	1.82	1.82				
Instalación	C2	40	3	3.81	0.90	4.23	169.17	2	17.62	1	17.62	AA2	135.00	106.00	2.00	0.62	2.44				
Instalación	C3	40	7	8.88	0.90	9.87	394.72	2	41.12	1	41.12	AA2	135.00	106.00	2.00	1.45	3.27				
Instalación	C4	40	3	3.81	0.90	4.23	169.17	2	17.62	1	17.62	AA2	135.00	106.00	2.00	0.62	3.89				
Instalación	C5	25	2	2.54	0.90	2.82	70.01	2	11.75	1	11.75	AA2	135.00	106.00	2.00	0.26	4.15				
Instalación	C7	68	6	7.61	0.90	8.46	571.02	2	35.24	1	35.24	AA2	135.00	106.00	2.00	2.10	2.10				
Instalación	C8	34	5	6.34	0.90	7.05	242.90	2	29.37	1	29.37	AA2	135.00	106.00	2.00	0.89	3.00				
USUARIOS	17	REGULACION MAXIMA															3.89				